



IFB 2016-0023 - ADDENDUM 1

BLAZING STAR LANE PROJECT Town of Hilton Head Island, South Carolina

Date Issued: July 25, 2016

Bid Opening 2:00 on August 1, 2016

Item 1. Questions and Answers from the Pre-Bid Meeting:

- Q1. When the trees are removed by the tree service, can they leave the stumps intact?
- A1. No, trees have already been removed and the stumps have been ground down. The contractor is required to clear and grub the area within the roadway construction lines in accordance with SCDOT Specification Earthwork, Section 201 Clearing and Grubbing and 201.4.3 Clearing and Grubbing within Roadway. As provided in this specification, clearing and grubbing extends to cut and fill slopes outside the roadway as needed and includes among other things the removal and disposal of stumps, roots and rubbish. These areas are clearly denoted on the plans where limits of disturbance, silt fencing, proposed grade lines & contours, and stormwater features are shown. The contractor shall clear and grade as needed within the R/W or easements as needed to complete the improvements. The Contractor shall tie in grades according to the cross sections and stabilize all denuded areas.
- Q2. Have there been any additions since these plans were released for IFB 2016-0011?
- A2. No, however several items have been removed from the bid schedule. See the new bid schedule issued with this addendum.
- Q3. Can the Town provide quantities for debris removal?
- A3. No. Debris removal will be completed under a separate contract and has been removed from the bid schedule as of the issuance of this addendum. Any remaining debris will be removed under specifications for clearing and grubbing and unclassified excavation.

Item 2. Attached: BLAZING STAR LANE PROJECT – EXHIBIT C. List of Estimated Quantities / Bid Schedule – IFB 2016-0023. Revised 7/21/16

Item 3. Attached: The following forms are provided for clarification of CDBG requirements during this project.

- 1) Form WH347 Payroll Reporting Form
- 2) SC47-2016-Wage Determination
- 3) Form HUD-11 Record of Employee Interview

Item 4. Attached: The geotechnical report including road corings has been provided as an attachment to the IFB and contract.

Item 5. Attached: Pre-bid Attendance List. Randy Kelly of Bennett Paving attended the Pre-Bid meeting but failed to sign in. His name and contact information has been added to the Pre-bid Attendance List and Bennett Paving is considered eligible to submit a bid.

Reminder: Bid Submittal Deadline is August 1, 2016 at 2:00 PM. All bid forms, documents, and certifications are required.